


UL TYPE EXAMINATION CERTIFICATE

Certificate No.	UL TEC-00372
Page	1/1
Date of Issue	2016-03-04
Applicant	Moonstar Electrical Switchgear Manufacturing LLC Po Box 48850 Dubai, UAE
Manufacturer	Moonstar Electrical Switchgear Manufacturing LLC Po Box 48850 Dubai, UAE
Product Sample Description	Low Voltage Switchgear and Control gear Assembly, Extendable, incorporating three phase and neutral busbar system and a protective busbar.
Designation	MDB-2500A
Ratings	Rated operational voltage (U_e): 415V Rated current of the ASSEMBLY (I_{nA}): 2500A Rated frequency: 50 Hz IP rating : IP 43
Product Sample Tested and found in compliance with Standard(s)	IEC 61439-1(ed. 2), IEC 61439-2(ed. 2)
Test Report Nos.	4786583089.8.1 issue date 2016-02-15
Additional information	N/A



Certification Manager
Jan-Erik Storgaard

Certification Body

This is to certify that the sample(s) of the Product described herein has been investigated to and found to have been in compliance with the Standard(s) indicated on this Certificate, in accordance with the UL Type Examination Certificate Program Requirements. This certificate and test results obtained apply only to the product sample(s) submitted by the Applicant. UL did not select the sample(s) or determine whether the sample(s) provided were representative of other manufactured products. UL has not established Follow-Up Service or other surveillance of the product. The Applicant/Manufacturer are solely and fully responsible for conformity of all products to all applicable Standard(s), specifications or requirements. The test results may not be used, in whole or in part, in any other document without UL's prior written approval.

**UL International Demko A/S, Borupvang 5A,
2750 Ballerup, Denmark, Tel. +45 44 85 65 65
info.dk@ul.com, www.ul.com**

